

Manual
MAXDOCK™

ARCHITECTURAL SPECIFICATIONS

PerforMax Industrial Doors
5 Crozerville Road, Aston, PA 19014
+1 (484) 840-8500

WWW.PERFORMAXGLOBAL.COM
INFO@PERFORMAXGLOBAL.COM

Part 1: General

1.1 General

Architectural Specifications describe criteria, product, manufacture delivery & installation of the MaxDock rubber door.

1.2 Product Specifics

- A. MaxDock rubber door has sturdy guides and a secure locking system to provide near airtight seal and breakaway feature for simple reinsertion.
- B. After accidental impact, the door must be resettable with normal tools and equipment.
- C. SBR rubber curtain for service temperature range of -40F to +180F (-40C to +85C), with proper heating cables when required.
- D. MaxDock rubber door to have 10,000 cycle spring.

1.3 Shop Drawings/Submittals

- A. Submit shop drawing showing all pertinent dimensions including: Shop Drawing, Product Data, Samples Electrical Requirements and Mock-Ups. Provide curtain or guide color samples as requested.
- B. Indicate each type of door and required clearances.
- C. Indicated installation handling.
- D. Requires sign off/approval on shop drawing & purchase order prior to manufacturing.

1.4 Installation Criteria

- A. Installer must be a factory authorized dealer.
- B. Field verification prior to shop drawing approval.

1.5 Warranty

- A. Limited Lifetime warranty on RhinoMax rubber curtain.
- B. One (1) year warranty on all other components.

Part 2: Products

2.1 Materials

- A. The MaxDock rubber door model and all components are manufactured & assembled by PerformMax Global.
- B. Substitutions will not be accepted.

2.2 Curtain Material

- A. Two (2) layers of Styrene Butadiene Rubber (SBR) each 3.2mm (1/8”) thick, 70 durometers; reinforced with 1-ply, 50kg (110lbs.) polyester cord center. Material provides normal resiliency and flexibility at temperatures ranging from -40F to +180F (-40C to +85C).
- B. End locks are attached to the edges of the curtain material. Curtain locks to be lubrication free. Rubber curtain should be free of edges.
- C. Standard Color: Black. Optional: Blue or Gray (EPDM rubber).

2.3 Guides

- A. Guides shall be two-piece rolled steel. End locks to move freely in the guides at all times. Steel guides to release curtain during impact yet remain rigid during normal operation.
- B. Side guide: Mounting steel guide is provided for installation directly onto concrete or steel door framing. Guides to be galvanized. Aluminum guides or hinged guides will not be accepted.

2.4 Bottom Bar

- A. Bottom bar shall extend the full operating width of the curtain. The bottom bar shall be constructed of two powder coated safety yellow steel angles bolted together and shall have a break out section to reduce risk of damage during accidental impacts. Spliced bottom bars or aluminum bottom bars will not be accepted.
- B. Bottom bar to have rubber loop astragal to seal against the ground.

2.5 Roll-Up Barrel

- A. The curtain is to be rolled on a tube of sufficient size to carry the door load with a deflection of not more than 2.5mm/m. Both the drive tube shafts are to be constructed of minimum 1 1/4” cold rolled steel shafts.
- B. 10,000 cycle springs concealed in seal spring pipe. Exposed torsion springs not acceptable.
- C. End brackets are constructed of rolled steel, self-aligning bearings with cast iron housings to support the drive tube.

2.6 Drive

- A. Manual chain hoist operation.

Part 3: Execution

3.1 Installation

- A. Install doors in accordance with manufacturer printed instructions by a factory trained & authorized installer.